

C (CLEARANCE TO REMOVE STRAINER FROM BELOW)
*IF THERE IS NOT ENOUGH CLEARANCE BELOW STRAINER,
PRODUCT CAN BE ROTATED 90° AXIALLY TO PROVIDE CLEARANCE
OR FOR STEAM APPLICATION TO MINIMIZE CONDENSATE COLLECTION

MATERIALS OF CONSTRUCTION

BODY, FLANGES, COVER PLATE - CAST IRON

STANDARD SCREENS

SERIVCE	SIZE	PERF		
LIQUID	2" - 3"	.045"		
LIQUID	4" - 8"	.125"		
STEAM	2" - 6"	.045"		
SIEAM	8"	.062"		

OPERATING TEMPERATURE/PRESSURE

WATER, OIL, GAS......175 PSI @ 150°F STEAM.....125 PSI @ 350°F

SCREEN - 304 STAINLESS STEEL STEAM......125 PSI @ 350°
O-RING GASKET - VITON

QTY PART NUMBER	PIPE SIZE		_	В	С	#Cv	SCREEN	PORT SIZE (NPT)		BLOWOFF	TAP SIZE	TAP	WEIGHT	
	NUMBER	INCH	MM	1 A	Б		(GPM)	AREA (in²)	1 & 2	3	SIZE (NPT)	(UNC)	DEPTH	(LBS)
	LPD0200	2"	50	7-7/8"	4-5/8"	9-5/8"	120	52.0	1/4"	1/2"	3/4"	5/8"-11	0.5"	20
	LPD0250	2-1/2"	65	10"	5-1/4"	11-7/8"	160	84.6	1/4"	1/2"	3/4"	5/8"-11	0.5"	30
	LPD0300	3"	80	10-1/8"	6-1/4"	12-7/8"	236	99.0	1/4"	1/2"	1"	5/8"-11	0.875"	50
	LPD0400	4"	100	12-1/8"	7-3/8"	15-1/4"	460	147.3	3/8"	1"	1"	5/8"-11	0.875"	75
	LPD0500	5"	125	15-5/8"	8-3/8"	19"	600	226.5	3/8"	1"	1-1/2"	3/4"-10	0.875"	115
	LPD0600	6"	150	18-1/2"	10-5/8"	23"	952	317.6	3/8"	1"	1-1/2"	3/4"-10	0.875"	154
	LPD0800	8"	200	22-1/2"	13"	28-3/8"	1580	515.0	3/8"	1"	1-1/2"	3/4"-10	1''	273

 $^{\sharp}$ CV is the flow rate in Gallons of 60°F water that will pass through the strainer in 1 minute at a 1 psi pressure drop.

NSF 372 - LEAD FREE

The wetted surface of this product contacted by consumable water contains less than one quarter of one percent (0.25%) of lead by weight. Material complies with state codes and standards, where applicable, requiring reduced lead content.

CUSTOMER:
PROJECT:
ENGINEER:

	9	C DIM AND STUD CALLOUT ADDED, 10"-16" ALLOCATED TO NEW SUBMITTAL	7/7/2022
	8	14" AND 16" ADDED	6/10/2020
	7	2-1/2" BLOWOFF ADJUSTED	4/12/2018
REV.	6	BLOWOFF ADJUSTED	DATE 12/6/2016



2323 W. HUBBARD ST. CHICAGO, IL 60612 TEL: 312-738-380 FAX: 312-738-0415 WWW.METRAFLEX.COM

MODEL LPD

LOW PRESSURE DROP 125# FLANGED STRAINER

DRAWN BY: D	KISH	DATE:	11/23/2015			
APPROVED: JR		DATE:	11/23/2015			
SCALE:	DRAWING NUMBER:					
N/A	IPD-8					